CERTIFICATE OF COMPLIANCE

Certificate Number	20190529-MH47144
Report Reference	MH47144-20130125
Issue Date	2019-MAY-29
Issued to:	KARL DUNGS INC SUITE 150, 3890 PHEASANT RIDGE DR NE BLAINE MN 55449
This certificate confirms that representative samples of	CONTROLS, PRIMARY SAFETY Primary safety control MPA4122; with combustion detector model 256-538UL-UV41 or 256-538UL-UV41HE; with or without Shutter Assembly UV4x EM1/1; with or without expansion board EM2/4, EM2/5 or EM2/6.
	Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL 353 , Standard for Limit Controls, Standard for Temperature-Indicating and -Regulating Equipment, CSA C22.2 No. 24
Additional Information:	See the UL Online Certifications Directory at https://iq.ulprospector.com for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/